



Physical Technical Testing Institute
Ostrava-Radvanice

(13)

Schedule

(14) **Type Examination Certificate N° FTZÚ 08 ATEX 0168X**

Type: PRIMA 236Ex; PRIMA 136Ex

Light source	Bi-pin linear fluorescent lamp 1;2 x 36W	
Type of ballast	inductance	electronic
Temperature class	T4	T5
T _{max.surface}	67°C	53°C

Type: PRIMA 218Ex; PRIMA 118Ex

Light source	Bi-pin linear fluorescent lamp 1;2 x 18W	
Type of ballast	inductance	electronic
Temperature class	T4	T5
T _{max.surface}	67°C	53°C

(16) Report No. : 08/0168 ... dated 13.10.2008

(17) Special conditions for safe use:


The installation of luminaire must be protected against mechanical damage.

(18) Essential Health and Safety Requirements:

Covered by standards mentioned in (9) of this certificate.

Responsible person:

Date of issue: 14.10.2008


Dipl. Ing. Šindler Jaroslav

Head of certification body



Number of pages: 3/4

This certificate is granted subject to the general conditions of the Physical Technical Testing Institute.
This certificate may only be reproduced in its entirety and without any change, schedule included.